

Non-Transient Consumer Notice of Tap Water Lead Result

Dear Consumer:

Field High School is a public water system (PWS) responsible for providing drinking water that meets state and federal standards. Drinking water samples were collected at the following locations. Results are summarized in the table below:

Sample Tap Location	Sample Collection Date	Lead Level Result (µg/L)	Greater or Less than the Lead Threshold Level (15 µg/L)
LC205 - Kitchen Hand Sink	9/24/2020	<2.0	less
LC207 - Home EC	9/24/2020	<2.0	less
LC206 - Mens Staff RR	9/24/2020	<2.0	less
LC210 - Room B3	9/24/2020	<2.0	less
LC203 - Room A10	9/24/2020	2.5	less
LC209 - Room D9	9/24/2020	2.6	less
LC201 - Room B4	9/24/2020	3.5	less
LC202 - Room C8	9/24/2020	4.8	less
LC204 - Room B6	9/24/2020	15	less
LC208 - Art Room	9/24/2020	63	greater

What Does This Mean?

Under the authority of the Safe Drinking Water Act, the US Environmental Protection Agency (EPA) established the action level for lead in drinking water at 15 micrograms per liter (µg/L). This means PWSs must ensure that water from taps used for human consumption do not exceed this level in at least 90 percent of the sites sampled (90th percentile value). The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a PWS must follow.

In 2018, Ohio EPA established the threshold level for lead in drinking water at 15 µg/L. The lead threshold level is the concentration of lead in an individual tap water sample which, if exceeded, triggers additional notification requirements for those served by the tap sampled. Additionally, if a sample exceeds the lead threshold level, the associated tap must be removed from service.

Because lead may pose serious health risks, US EPA established a Maximum Contaminant Level Goal (MCLG) of zero for lead. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health, allowing for a margin of safety.

What are the Health Effects of Lead?

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development.

Where Can I Get Health Screenings and Testing of Blood Lead Levels?

Health Screenings are available through your personal care physician. Please contact them for more information.

What Can I Do to Reduce Exposure to Lead if Found in My Drinking Water?

- ***Run your water to flush out lead.*** If water has not been used for several hours, run water for thirty seconds to two minutes before using it for drinking or cooking. This helps flush any lead in the water that may have leached from the plumbing.
- ***Use cold water for cooking and preparing baby formula.*** Do not cook with, drink water, or make baby formula from the hot water tap. Lead dissolves more easily in hot water.
- ***Do not boil water to remove lead.*** Boiling water will not reduce lead.

What are the Sources of Lead?

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like rivers and lakes. Lead enters drinking water primarily as a result of corrosion, or wearing away, of materials containing lead in the plumbing. Buildings built prior to 1986 are more likely to have lead pipes, fixtures, and solder. New buildings can also be at risk, since even legally 'lead-free' plumbing may contain up to 8 percent lead. The most common problem is with brass or chrome-plated brass fixtures which can leach significant amounts of lead into water, especially hot water.

For More Information, Please Contact: Tim Fox 330-673-2659; visit US EPA's Web site at www.epa.gov/lead; call the National Lead Information Center at 800-424-LEAD; or contact your health care provider.

Verification of Lead Consumer Notice Issuance

PWS Name: Field High School Drinking Water Program - Compliance Notification
 PWS ID: 6740112 County: Portage

Submit this completed verification form within 5 business days of receipt of lead sample results. Submit to Ohio EPA DDAGW Central Office via email (preferred): DDAGW_lead_CN@epa.ohio.gov; fax: 614-644-2909; or mail: Ohio EPA - DDAGW, 50 West Town Street, Suite 700, Columbus, OH 43216 , Subject: Lead Consumer Notice.

Lead Consumer Notice Requirements

All lead results:

1. Issue Consumer Notice within two business days of receipt of lead sample results.
2. Deliver Consumer Notice to the owner and persons served from the sample location using one of the following methods:
 - For results less than 15 µg/L: E-mail, hand delivery, phone call, or mail
 - For results greater than 15 µg/L: E-mail, hand delivery, phone call with written follow up (mail, e-mail, or hand delivery)
 - Any result (NTNC and Small Community Systems only): Post near sample location for a minimum of 7 days.
3. If your facility is a school, daycare, nursing home, or a juvenile correctional institution, notify legal guardians or power of attorney. Please indicate if your facility is a school, daycare, nursing home, or correctional institution by checking the following box:

Any individual lead result greater than 15 µg/L:

4. Within two business days of receipt of lead sample results, notify local health department of results.
5. Include information regarding the availability of health screenings and testing of lead blood levels in the CN.
6. For NTNC systems only, immediately remove from service all fixtures with results greater than 15 µg/L.

Fill in all sample data on the following page(s) and include all applicable information to verify lead consumer notice was issued in accordance with the requirements outlined above. Retain a copy of this report in your files with supporting documentation for a minimum of 12 years.

Include a representative copy of all CNs issued for lead samples below 15 µg/L and one copy of each CN for lead samples above 15 µg/L.

By signing this document, whether handwritten or typed, I am providing a legal signature confirming that I acknowledge and warrant the truthfulness of the information provided in this document. I hereby certify that the Lead Consumer Notice was issued to all locations that were sampled by the dates specified on the following page(s). Issuance was made by the method(s) indicated.

			
Signature of Responsible Official	Printed Name	Title	Date

For Ohio EPA use only		CN Verification Received Date: _____	
CN on time:	CN late:	CN Acceptable:	CN Not Acceptable:

Sampling Data						
Fill in all applicable information below to verify lead consumer notice was issued in accordance with the requirements. Add additional rows as needed.						
If a sample was submitted as DS000, include the sample location and address and submit an updated SMP ID Spreadsheet to your Ohio EPA District Office, as applicable.						
Sample Location (LC### or Address and Sample Location)	CN Delivery Date	CN Delivery Method (Choose from drop down)	Lab Sample Number	For any samples greater than 15 µg/L, check applicable boxes below		
				Included info on health screening and lead blood level tests in CN	Notified Health Department	Removed fixture from service (NTNC Only)
LC205 - Kitchen Hand Sink	10-12-20	Email	7077			
LC207 - Home EC	10-12-20	Email	7078			
LC206 - Mens Staff RR	10-12-20	Email	7076			
LC210 - Room B3	10-12-20	Email	7074			
LC203 - Room A10	10-12-20	Email	7075			
LC209 - RoomD9	10-12-20	Email	7079			
LC201 - Room B4	10-12-20	Email	7073			
LC202 - Room C8	10-12-20	Email	7071			
LC204 - Room B6	10-12-20	Email	7072			
LC208 - Art Room	10-12-20	Email	7080	yes	10-12-20	10-9-20

Non-Transient Consumer Notice of Tap Water Lead Result

Dear Consumer:

Field Middle School is a public water system (PWS) responsible for providing drinking water that meets state and federal standards. Drinking water samples were collected at the following locations. Results are summarized in the table below:

Sample Tap Location	Sample Collection Date	Lead Level Result (µg/L)	Greater or Less than the Lead Threshold Level (15 µg/L)
LC210 - Clinic	9/24/2020	<2.0	less
LC206 - Boys RR by 117	9/24/2020	<2.0	less
LC205 - Boys RR Lower	9/24/2020	<2.0	less
LC207 - Kitchen Hand Sink	9/24/2020	<2.0	less
LC202 - Girls RR Upper	9/24/2020	<2.0	less
LC201 - Boys RR Upper	9/24/2020	<2.0	less
LC203 - Kitchen Veggie Sink	9/24/2020	<2.0	less
LC209 - Boys Locker Room	9/24/2020	<2.0	less
LC208 - Art Room	9/24/2020	3.6	less
LC204 - Girls RR by 117	9/24/2020	15	less

What Does This Mean?

Under the authority of the Safe Drinking Water Act, the US Environmental Protection Agency (EPA) established the action level for lead in drinking water at 15 micrograms per liter (µg/L). This means PWSs must ensure that water from taps used for human consumption do not exceed this level in at least 90 percent of the sites sampled (90th percentile value). The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a PWS must follow.

In 2018, Ohio EPA established the threshold level for lead in drinking water at 15 µg/L. The lead threshold level is the concentration of lead in an individual tap water sample which, if exceeded, triggers additional notification requirements for those served by the tap sampled. Additionally, if a sample exceeds the lead threshold level, the associated tap must be removed from service.

Because lead may pose serious health risks, US EPA established a Maximum Contaminant Level Goal (MCLG) of zero for lead. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health, allowing for a margin of safety.

What are the Health Effects of Lead?

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development.

Where Can I Get Health Screenings and Testing of Blood Lead Levels?

Health Screenings are available through your personal care physician. Please contact them for more information.

What Can I Do to Reduce Exposure to Lead if Found in My Drinking Water?

- ***Run your water to flush out lead.*** If water has not been used for several hours, run water for thirty seconds to two minutes before using it for drinking or cooking. This helps flush any lead in the water that may have leached from the plumbing.
- ***Use cold water for cooking and preparing baby formula.*** Do not cook with, drink water, or make baby formula from the hot water tap. Lead dissolves more easily in hot water.
- ***Do not boil water to remove lead.*** Boiling water will not reduce lead.

What are the Sources of Lead?

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like rivers and lakes. Lead enters drinking water primarily as a result of corrosion, or wearing away, of materials containing lead in the plumbing. Buildings built prior to 1986 are more likely to have lead pipes, fixtures, and solder. New buildings can also be at risk, since even legally 'lead-free' plumbing may contain up to 8 percent lead. The most common problem is with brass or chrome-plated brass fixtures which can leach significant amounts of lead into water, especially hot water.

For More Information, Please Contact: Tim Fox 330-673-2659; visit US EPA's Web site at www.epa.gov/lead; call the National Lead Information Center at 800-424-LEAD; or contact your health care provider.

Verification of Lead Consumer Notice Issuance

PWS Name: Field Middle School Drinking Water Program - Compliance Notification
 PWS ID: 6740212 County: Portage

Submit this completed verification form within 5 business days of receipt of lead sample results. Submit to Ohio EPA DDAGW Central Office via email (preferred): DDAGW_lead_CN@epa.ohio.gov; fax: 614-644-2909; or mail: Ohio EPA - DDAGW, 50 West Town Street, Suite 700, Columbus, OH 43216, Subject: Lead Consumer Notice.

Lead Consumer Notice Requirements

All lead results:

1. Issue Consumer Notice within two business days of receipt of lead sample results.
2. Deliver Consumer Notice to the owner and persons served from the sample location using one of the following methods:
 - For results less than 15 µg/L: E-mail, hand delivery, phone call, or mail
 - For results greater than 15 µg/L: E-mail, hand delivery, phone call with written follow up (mail, e-mail, or hand delivery)
 - Any result (NTNC and Small Community Systems only): Post near sample location for a minimum of 7 days.
3. If your facility is a school, daycare, nursing home, or a juvenile correctional institution, notify legal guardians or power of attorney. Please indicate if your facility is a school, daycare, nursing home, or correctional institution by checking the following box:

Any individual lead result greater than 15 µg/L:

4. Within two business days of receipt of lead sample results, notify local health department of results.
5. Include information regarding the availability of health screenings and testing of lead blood levels in the CN.
6. For NTNC systems only, immediately remove from service all fixtures with results greater than 15 µg/L.

Fill in all sample data on the following page(s) and include all applicable information to verify lead consumer notice was issued in accordance with the requirements outlined above. Retain a copy of this report in your files with supporting documentation for a minimum of 12 years.

Include a representative copy of all CNs issued for lead samples below 15 µg/L and one copy of each CN for lead samples above 15 µg/L.

By signing this document, whether handwritten or typed, I am providing a legal signature confirming that I acknowledge and warrant the truthfulness of the information provided in this document. I hereby certify that the Lead Consumer Notice was issued to all locations that were sampled by the dates specified on the following page(s). Issuance was made by the method(s) indicated.

 _____ Signature of Responsible Official	Tim Fox _____ Printed Name	Director Operations _____ Title	10-12-20 _____ Date
---	----------------------------------	---------------------------------------	---------------------------

For Ohio EPA use only		CN Verification Received Date: _____	
CN on time:	CN late:	CN Acceptable:	CN Not Acceptable:

Sampling Data						
Fill in all applicable information below to verify lead consumer notice was issued in accordance with the requirements. Add additional rows as needed. If a sample was submitted as DS000, include the sample location and address and submit an updated SMP ID Spreadsheet to your Ohio EPA District Office, as applicable.						
Sample Location (LC### or Address and Sample Location)	CN Delivery Date	CN Delivery Method (Choose from drop down)	Lab Sample Number	For any samples greater than 15 µg/L, check applicable boxes below		
				Included info on health screening and lead blood level tests in CN	Notified Health Department	Removed fixture from service (NTNC Only)
LC210 - Clinic	10-2-20	Email	7081			
LC206 -Boys RR by 117	10-12-20	Email	7085			
LC205 - Boys RR Lower	10-12-20	Email	7086			
LC207 Kitchen Hand Sink	10-12-20	Email	7089			
LC202 - Girls RR Upper	10-12-20	Email	7087			
LC201 - Boys RR Upper	10-12-20	Email	7088			
LC203 - Kitchen Veggie Sink	10-12-20	Email	7090			
LC209 - Boys Locker Room	10-12-20	Email	7082			
LC208 - Art Room	10-12-20	Email	7083			
LC204 - Girls RR by 117	10-12-20	Email	7084			